



SAMPLE EROSION AND SEDIMENT CONTROL INSPECTION FORM

PROJECT LOCATION (Site Address) 123 S. 10th St, Rain OR		PROJECT LOCATION (Township, Range, Section, Tax Lot) 01S, 01W, 88, TL 444		PERMIT NUMBER(S) 23-000	
CONTRACTOR/SUBCONTRACTOR NAME ABC Contractor			ADDRESS Business Address		PHONE 555-867-5309

1. Identify the Erosion Control Measures from the ESCP:

EROSION CONTROL MEASURES	DATE INSTALLED	FUNCTIONING AS DESIGNED?	DESCRIBE WHAT IS NOT FUNCTIONING	LOCATION OF DEFICIENCY	CORRECTIVE ACTION	DATE CORRECTIVE ACTION COMPLETE	IS THERE VISIBLE OR MEASURABLE SEDIMENT?	HAS SEDIMENT ENTERED A BODY OF WATER?	DATE MEASURE REMOVED
sediment fence	1/5/23	Y	N/A	N/A	N/A	N/A	Y	N	
plastic sheeting	1/6/23	N	tear in plastic	top NE side	replaced plastic	1/22/23	N	N	2/22/23

DESCRIBE ANY EROSION CONTROL MEASURES NOT LISTED ABOVE

2. Add or Attach Any Additional Information as Needed:

ADDITIONAL INFORMATION MAY BE INCLUDED IN THIS FIELD or ATTACHED TO THIS REPORT

3. Weekly Rainfall Amounts:

RAINFALL REPORTING STATION <small>rain gauge on fence post or on-line weather report site</small>	MONITORING PERIOD 2/6 to 2/12	<input checked="" type="checkbox"/> ACTIVE	24-HOUR RAINFALL AMOUNT:	0.01	0.00	0.14	0.06	0.02	0.11	0.04
	<input type="checkbox"/> INACTIVE	ENDING DATES:	2/6/23	2/7/23	2/8/23	2/9/23	2/10/23	2/11/23	2/12/23	

4. Signature:

PRINTED NAME Inspector's Name	SIGNATURE Inspector's Name	DATE Date of Inspection	PHONE Inspector's Phone
---	--------------------------------------	-----------------------------------	-----------------------------------

Minimum Monitoring Requirements: Inspect all erosion control facilities at least every 7 calendar days on active sites and two weeks on inactive sites. Inspect daily during stormwater or snowmelt runoff and within 24 hours after more than 0.5 inch of rain per 24-hour period. See Linn County Erosion and Sediment Control Manual for additional information.